



October 25, 2017

Mr. John Willford
Mount Diablo Unified School District

Structural Engineers, Inc.

Subject: Concord High School
Interior Bleachers

Dear Mr. Willford:

This letter is regarding the new interior folding bleachers at Concord High School.

The manufacturer proposed tying the bleachers to the Gymnasium concrete walls.

Based on DSA review and comments, our recommendations are to support the bleachers structure on piers independent from the walls.

Sincerely,

TSA Structural Engineers Inc
Tony Samra, Principal Structural Engineer.

433 Airport Blvd., Suite 106E
Burlingame, California 94010
T 650-620-9555
F 650-620-9559

www.tsase.com

